

FWSA.EX27228 - Fixed Condensed Aerosol Extinguishing System Units

Fixed Condensed Aerosol Extinguishing System Units

[See General Information for Fixed Condensed Aerosol Extinguishing System Units](#)

GREENEX FIRE SUPPRESSION SOLUTIONS BV

St. Jansgildestraat 53
7037 CB Beek, THE NETHERLANDS

EX27228

Description	Part No.
Aerosol-generating extinguishing system unit	
GreenEx condensed aerosol generator	A-50
GreenEx condensed aerosol generator	A-100
GreenEx condensed aerosol generator	A-200
GreenEx condensed aerosol generator	A-500
GreenEx condensed aerosol generator	A-1000
GreenEx condensed aerosol generator	A-5000
Mounting bracket, 50 g	370853
Mounting bracket, 100 g	370485
Mounting bracket, 200 g	370598
Mounting bracket, 500 g and 1000 g	370690
Mounting brackets, 5000 g	370807, 370829
Design, Installation, Operation and Maintenance Manual, Version Rev. 8, dated March 2016	GreenSolManual

For Class A surface burning and Class B and C category hazards; not for use in hazardous (classified) locations. Temperature range -40 to +54°C.

Trademark and/or Tradename: "GreenEx", "GreenSol",



Last Updated on 2020-10-09

并不是所有出现在本数据库中的公司名称和产品都满足了UL跟踪检验服务的要求。只有带有UL标志的产品，才应该被视为经过UL认证，并满足UL跟踪检验服务的要求。注意查看产品上的标志。

UL允许在线认证目录中所含材料的复制遵循以下条件：1.指南信息、装配、构造、设计、系统和/或认证（文件）必须在不篡改任何数据（或图纸）的情况下完整且无误导性地呈现。2.“经UL允许从在线认证目录转载”声明必须出现在所摘取材料的邻近位置。此外，转载材料必须包含以下格式的版权声明：“© 2020 UL LLC”