

FWSA7.EX27228 - Fixed Condensed Aerosol Extinguishing System Units Certified for Canada

Fixed Condensed Aerosol Extinguishing System Units Certified for Canada


See General Information for Fixed Condensed Aerosol Extinguishing System Units Certified for Canada

GREENEX FIRE SUPPRESSION SOLUTIONS BV
 St. Jansgildestraat 53
 7037 CB Beek, THE NETHERLANDS

EX27228

Description	Part No.
Aerosol-generating extinguishing system unit	
GreenEx condensed aerosol generator	A-50
GreenEx condensed aerosol generator	A-100
GreenEx condensed aerosol generator	A-200
GreenEx condensed aerosol generator	A-500
GreenEx condensed aerosol generator	A-1000
GreenEx condensed aerosol generator	A-5000
Mounting bracket, 50 g	370853
Mounting bracket, 100 g	370485
Mounting bracket, 200 g	370598
Mounting bracket, 500 g and 1000 g	370690
Mounting brackets, 5000 g	370807, 370829
Design, Installation, Operation and Maintenance Manual, Version Rev. 8, dated March, 2016	GreenSolManual

For Class A surface burning and Class B and C category hazards; not for use in hazardous (classified) locations. Temperature range -40 to +54°C.

Trademark and/or Tradename: "GreenEx", "GreenSol", 

Last Updated on 2020-10-09

并不是所有出现在本数据库中的公司名称和产品都满足了UL跟踪检验服务的要求。只有带有UL标志的产品，才应该被视为经过UL认证，并满足UL跟踪检验服务的要求。注意查看产品上的标志。

UL 允许在线认证目录中所含材料的复制遵循以下条件：1.指南信息、装配、构造、设计、系统和/或认证（文件）必须在不篡改任何数据（或图纸）的情况下完整且无误导性地呈现。2.“经 UL 允许从在线认证目录转载”声明必须出现在所摘取材料的邻近位置。此外，转载材料必须包含以下格式的版权声明：“© 2020 UL LLC”